

Message

From: Hi Sang Kim [hi-sang.kim@lacity.org]
Sent: 11/25/2021 12:08:24 AM
To: Magnan, Eric [Magnan.Eric@epa.gov]
CC: Mitschele, Becky [Mitschele.Becky@epa.gov]; Barbara Romero [barbara.romero@lacity.org]; Minamide, Traci [traci.minamide@lacity.org]; Dafeta, Timeyin [timeyin.dafeta@lacity.org]; Dojiri, Mas [mas.dojiri@lacity.org]; Mohamed, Farhana [farhana.mohamed@lacity.org]; Bell, Ronald [ronald.bell@lacity.org]; Mayuyu, Ronald [ronald.mayuyu@lacity.org]
Subject: Re: HTP-R4-2017-0045, Proposed Functional Testing of 1-Mile Outfall Gates
Attachments: HTP-R4-2017-0045-1-Mile-Lab Data.xlsx

Mr. Magnan

Attached file contains the laboratory data for the effluent and offshore samples taken during the 1-Mile Outfall gate exercise.

If you have any questions, please let me know. Thank you.

On Fri, Nov 19, 2021 at 11:06 AM Hi Sang Kim <hi-sang.kim@lacity.org> wrote:

Mr. Magnan:

The 1-Mile Outfall gates' planned exercise was completed successfully as scheduled on November 17 and 18. All three gates were opened and closed successfully from the local and remote locations. The discharged secondary effluent to the 1-Mile Outfall (total 500,000 gallons, 250,000 from the East Channel and 250,000 from the West Channel) was disinfected and pumped back to the plant. Once the test results of the secondary effluent are available, they will be reported to the Los Angeles Regional Water Board.

If you have any questions, please contact me by email or phone, 310-648-5507.

On Wed, Nov 3, 2021 at 2:39 PM Hi Sang Kim <hi-sang.kim@lacity.org> wrote:

Mr. Magnan:

Hyperion Treatment Plant is notifying the USEPA, Region 9 of the planned 1-Mile Outfall Gates' functional testing on Nov 17 and 18, 2021. Please review the attached letter for the notification and the inspection report of the 1-Mile diversion structure and surge chamber, as required by the Permit.

If you have any questions, please contact me by email or phone, 310-648-5507.